


ISO 9509 Nitrification Inhibition Study



Presenters

Geoff Hinshelwood

Universal Laboratories

geoff@universallaboratories.net

Duane Wilding

Maryland Environmental Service

Background


Midshore Regional Landfill discharged leachate to Easton wastewater lagoon system

Easton's new ENR WWTP – concerns with treating leachate due to potential toxicity or inhibition with sensitive nitrification processes


MES requested to demonstrate “no toxicity or inhibition” of leachate



Composite Data



Principal Concerns



- High NH_3 in Leachate representing 5 - 15 % of Influent
- Heavy metals, e.g., zinc – High spikes with generally low values
- Sufficient storage during wet weather flow

Nitrification/ DeNitrification



NH_4^+ - oxidizing bacteria oxidize NH_4^+ to NO_2^-




NO_3^- -oxidizing bacteria oxidize NO_2^- to NO_3^-

ISO 9509

- ISO 9509 second edition
2006-07-01
- Toxicity test for assessing the inhibition of nitrification of activated sludge microorganisms
- ISO Method expanded to include testing for “denitrification”





Lessons Learned



Easton Wet Bench



Easton aeration set-up



Test Results

Total of 30 test vessels for nitrification

Total of 20 test vessels for denitrification

No inhibition was observed



Summary Data Table 3

Summary Nitrate Table (mg/L of NO ₃)					
	run 1	run 2	run 3	run 4	run 5
Control	48.88	32.02	27.80	49.05	43.85
Inhibited Control	4.30	2.28	3.32	2.28	5.62
cylinder 4	39.55	58.20	25.45	36.15	49.20
cylinder 3	48.40	34.70	37.65	28.60	10.70
cylinder 2	37.60	49.10	35.52	32.60	48.50
cylinder 1	95.80	54.00	15.60	14.60	20.60

ANOVA Data Table 4

<i>Groups</i>	<i>Count</i>	<i>Sum</i>	<i>Average</i>	<i>Variance</i>
Control	5	201.6	40.32	96.89
Cylinder 4	5	208.55	41.71	156.99
Cylinder 3	5	160.05	32.01	193.35
Cylinder 2	5	203.32	40.664	58.36
Cylinder 1	5	200.6	40.12	1231.6

Lessons Learned

1. This type of testing is needed due to new ENR processes being used
2. Only nitrification testing can determine inhibition to ENR processes.
3. Need to have “fresh” mixed liquor
4. Recommend regular “nitrification rate” testing to regularly monitor process performance.



Outcome of Testing

- @ Results presented to MDE and Easton Utilities on Jan. 16, 2007
- @ EU to allow discharge of untreated leachate for a trial period of 3 months
- @ Presently discharging with no impact
- @ 20 gal/min from 6 am to 12 midnight and 10 gal/min from midnight to 6 am

Conclusions / Summary

- Testing allowed receiving approval to discharge untreated leachate for a trial period
- Will save several millions dollars
- MES will pay Easton Utilities a surcharge for treating the high strength wastes.

Acknowledgements:

- Easton Utilities Staff
- Maryland Department of the Environment
- Stearns & Wheler Staff
- Landfill staff
- Universal Laboratories Staff